Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QJ211

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRAAKSMA, RANDALL			Phone #: (715)424-5353
Mailing Address: 3820 HERITAGE RIDGE DR			
City: WISCONSIN RAPIDS	State: WI	Zip Code: 54494	
County: Wood	Co. Permit #:	Notification #:	Completed: 09-01-2002

1. Well Location

Town of GRAND RAPIDS

Fire # (if avail.):

Street Address or Road Name and Number: 3820 HERITAGE RIDGE DR

Subdivision Name	Lot #	Block #
HERITAGE RIDGE	5	

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ROTH PLUMBING & WELL DRILLING	5857	

Latitude / Longitude in Decimal Degree (DD): 44.3598 °N -89.7529 °W

Method Code: GCD013

Well Plan Approval #:

SW NE or Govt Lot #	Section	Township	Range
	26	22 N	6 E

Address: 618 HWY 73 S
NEKOOSA WI 54457

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		7.5

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	41.1

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	37
-	A	Y	-	CRS SAND & GRAVEL	37	41.1

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	SAWHILL ASTM A53B 6.625 X .280 EL 21 HT A13786 2/02 WELDED	Surface	38.1
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON SS 12 SLOT	38.1	41.1

9. Static Water Level

23 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 15 GP for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		09-04-2002
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		57	Building Overhang		2
			Wastewater Sump		64

Comment:

Created On: 10-02-2002 Updated On: 05-05-2020 Review Status: