Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QJ212

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SZMAJBA, FRANK	Phone #
Mailing Address: 2013 W COURTLAND	
City: CHICAGO	State: IL — Zip Code: 60647
County: Adams	Co. Permit #	Notification #	Completed: 09-14-2002

1. Well Location

Town of ROME

Fire # (if avail.)

Street Address or Road Name and Number: 1484 SPYGLASS CT

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): ROTH PLUMBING & WELL DRILLING	Lic. #: 5857	Facility ID # (Public Wells)
Address: 618 HWY 73 S NEKOOSA WI 54457		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 12.5

Latitude / Longitude in Decimal Degree (DD): 44.2036 °N -89.8555 °W — Method Code: GCD013

NW	SW	Section	Township	Range
or Govt Lot #		13	20 N	5 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	58.3

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	N	S	-	FINE SAND	Surface	32
-	-	S	-	SAND	32	40
-	A	S	-	CRS SAND	40	52
-	A	Y	-	CRS SAND & GRAVEL	52	58.3

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	WHEATLAND ASTM A-53 6.625 X .280 BEL 21 HT B 21249 6/02 WELDED	Surface	54.3
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON SS 12 SLOT	54.3	58.3

9. Static Water Level

39 ft. below ground surface

10. Pump Test

Pumping level 41 ft. below surface

Pumping at 25 GP for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		09-16-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		27	Building Overhang		9

Comment:

Created On: 10-02-2002 Updated On: 05-04-2020 Review Status: