

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QJ213		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner PETERSON, STEWART						Phone # (715)325-3195		1. Well Location				Fire # (if avail.)			
Mailing Address 320 HUNTINGTON CT						Town of ROME						Street Address or Road Name and Number 320 HUNTINGTON CT			
City NEKOOSA				State WI		Zip Code 54457		Subdivision Name				Lot #		Block #	
County Adams		Co. Permit #		Notification #		Completed 10-11-2002		Latitude / Longitude in Decimal Degree (DD) 44.2113 °N -89.7902 °W				Method Code GCD013			
Well Constructor (Business Name) ROTH PLUMBING & WELL DRILLING				Lic. # 5857		Facility ID # (Public Wells)		NE NW Section Township Range or Govt Lot # 16 20 N 6 E		2. Well Type Replacement			of previous unique well # constructed in		
Address 618 HWY 73 S NEKOOSA WI 54457				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ? OLD WELL FAILING							
Hicap Permanent Well #				Common Well #		Specific Capacity 12.5		Construction Type Drilled							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		62											
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - S -				SAND				Surface		39					
- A Y -				CRS SAND & GRAVEL				39		40					
- - C -				CLAY				40		50					
- A S -				CRS SAND				50		55					
- A Y -				CRS SAND & GRAVEL				55		62					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6.625		WHEATLAND ASTM A53 6.625 X .280 BEL 21 HT B 21249 6/02 (WELDED)				Surface		58							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		JOHNSON S.S.				58		62							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
				Surface											
9. Static Water Level															
23.6 ft. below ground surface															
10. Pump Test															
Pumping level 25.6 ft. below surface Pumping at 25 GP M for 2 Hrs. Pumping Method ?															
11. Well Is															
18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
RR				Lic #		Date Signed		10-20-2002							
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		56	Downspout/Yard Hydrant		9
Building Drain - Sanitary		11	Sewer - Building Sanitary		33
Building Overhang		5	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-09-2003

Updated On: 05-04-2020

Review Status: