

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QJ288		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																													
Property Owner A C BUILDERS						Phone #		1. Well Location				Fire # (if avail.)																											
Mailing Address S70 W32185 WHITE TAI						Village of DOUSMAN																																	
City MUKWONAGO						State WI		Zip Code 53149				Street Address or Road Name and Number 37420 STILL WATER																											
County Waukesha		Co. Permit #		Notification #		Completed 12-16-2002		Subdivision Name				Lot # Block #																											
Well Constructor (Business Name) RICHARD MORSE				Lic. # 619		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code																											
Address S78 W32552 SUGDEN RD MUKWONAGO WI 53149				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW SW Section Township Range or Govt Lot # 34 7 N 17 E		2. Well Type New Well UV428 replaces this well of previous unique well # constructed in																													
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ?																																	
3. Well serves 1 # of				Hicap Well ? No																																			
Private, potable				Hicap Property ? No																																			
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled																																	
4. Potential Contamination Sources - ON REVERSE SIDE																																							
5. Drillhole Dimensions and Construction Method																																							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology																													
6		Surface		187		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>-</td><td>-</td><td>G</td><td>-</td><td>GRAVEL</td><td>Surface</td><td>7</td> </tr> <tr> <td>-</td><td>-</td><td>S</td><td>-</td><td>SAND</td><td>7</td><td>23</td> </tr> <tr> <td>-</td><td>-</td><td>C</td><td>S</td><td>SANDY CLAY</td><td>23</td><td>182</td> </tr> <tr> <td>-</td><td>-</td><td>S</td><td>-</td><td>SAND</td><td>182</td><td>187</td> </tr> </table>		-	-	G	-	GRAVEL	Surface	7	-	-	S	-	SAND	7	23	-	-	C	S	SANDY CLAY	23	182	-	-	S	-	SAND	182	187
-	-	G	-	GRAVEL	Surface	7																																	
-	-	S	-	SAND	7	23																																	
-	-	C	S	SANDY CLAY	23	182																																	
-	-	S	-	SAND	182	187																																	
6. Casing, Liner, Screen						9. Static Water Level			11. Well Is																														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10 ft. below ground surface																													
6		STEEL 19# ASTMA53 SAWHILL WELDED				Surface		184		14 in. above grade																													
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test																													
5		STAINLESS 15 SLOT				184		187		Pumping level 160 ft. below surface Pumping at 7 GP M for 6 Hrs. Pumping Method ?																													
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?																																	
Method						Filled & Sealed Well(s) as needed?																																	
Kind of Sealing Material		From (ft.)		To (ft.)								# Sacks Cement																											
		Surface																																					
						13. Constructor / Supervisory Driller			Lic #		Date Signed																												
						RM					12-17-2002																												
						Drill Rig Operator			Lic or Reg #		Date Signed																												

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		77	Building Overhang		17
			Septic or Holding, or POWTS Tank		53

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	04/12/2010	HOLE PLUG 0-157' 45 SACKS USED	LOW GPM

Created On: 01-10-2003

Updated On: 04-19-2010

Review Status: