Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QJ288

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: A C BUILDERS			Phone #
Mailing Address: S70 W32185 WHITE TAI			
City: MUKWONAGO	State: WI	Zip Code: 53149	
County: Waukesha	Co. Permit #	Notification #	Completed: 12-16-2002

Well Constructor (Business Name): RICHARD MORSE	Lic. #: 619	Facility ID # (Public Wells)	
Address: S78 W32552 SUGDEN RD MUKWONAGO WI 53149		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Village of DOUSMAN

Fire # (if avail.)

Street Address or Road Name and Number: 37420 STILL WATER

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W — Method Code

NW SW or Govt Lot #	Section: 34	Township: 7 N	Range: 17 E

2. Well Type New Well — UV428 replaces this well of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	187

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	G	-	GRAVEL	Surface	7
-	-	S	-	SAND	7	23
-	-	C	S	SANDY CLAY	23	182
-	-	S	-	SAND	182	187

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 19# ASTMA53 SAWHILL WELDED	Surface	184
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS 15 SLOT	184	187

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 160 ft. below surface
Pumping at 7 GP M for 6 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RM		12-17-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		77	Building Overhang		17
			Septic or Holding, or POWTS Tank		53

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	04/12/2010	HOLE PLUG 0-157' 45 SACKS USED	LOW GPM

Created On: 01-10-2003 Updated On: 04-19-2010 Review Status: