Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: QJ294

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ARTISAN HOMES			Phone #
Mailing Address: 1602 E JUNIPER WAY			
City: HARTLAND	State: WI	Zip Code: 53029	
County: Waukesha	Co. Permit #	Notification #	Completed: 02-12-2003

Well Constructor (Business Name): RICHARD MORSE	Lic. #: 619	Facility ID # (Public Wells)	
Address: S78 W32552 SUGDEN RD MUKWONAGO WI 53149		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity	

1. Well Location

Town of DELAFIELD

Fire # (if avail.)

Street Address or Road Name and Number: N42 W28968 IMPERIAL DR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 43.0939 °N -88.3227 °W

Method Code: GCD013

NW	SW	Section	Township	Range
or Govt Lot #		1	7 N	18 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	35

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Z	-	CLAY GRAVEL	Surface	19
-	-	G	-	GRAVEL	19	32
-	-	Y	-	SAND GRAVEL	32	35

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 19# ASTMA 53 SAWHILL WELDED	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS 15 SLOT	33	35

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

7 ft. below ground surface

10. Pump Test

Pumping level 7 ft. below surface

Pumping at 15 GP for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RM		
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		14	Collector Sewer - San or Storm		79
			Sewer - Building Sanitary		54

Comment:

Inspection Type	Inspection Date	Inspection Request Date	Problem Noted Text
	01/29/2003		N PAYNE STOPPED.

Created On: 03-05-2003 Updated On: 07-12-2019 Review Status: