

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QJ626		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner REIMANN, JIM & BONNIE						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 4400 HAMILTON DR						Town of CEDAR LK									
City EGAN						State MN		Zip Code 55123				Street Address or Road Name and Number 28 1/8 ST			
County Barron		Co. Permit #		Notification #		Completed 09-30-2001		Subdivision Name LOCH LOMAN #3				Lot # 4-13-		Block #	
Well Constructor (Business Name) THOMAS J RUTHERFORD				Lic. # 4719		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address 2795 23 1/2 ST PO BOX 6 BRILL WI 54818				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE SW Section Township Range or Govt Lot # 14 36 N 10 W							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?									
3. Well serves 1 # of CAMPER Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock						
4		Surface		69											
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T	Q	Y	-	BROWN CAVING & GRAVEL				Surface		18					
-	-	C	G	CLAY LAYERS GRAVEL				18		26					
R	-	-	U	REDISH MUCK				26		30					
T	N	S	-	BROWN FINE SAND				30		69					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4		IPSCO ASTM A53B 10.79 237				Surface		66							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
3		WELDED STAINELSS #10 SLOTTED				66		69							
7. Grout or Other Sealing Material															
Method BNTONITE MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
				Surface											
9. Static Water Level															
36 ft. below ground surface															
10. Pump Test															
Pumping level 55 ft. below surface Pumping at 12 GP for 12 Hrs. Pumping Method ?															
11. Well Is															
16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? WERE NONE															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
TR										10-01-2001					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Building Sanitary		35	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 03-14-2002

Updated On: 03-14-2002

Review Status: