Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QJ626

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: REIMANN, JIM & BONNIE	Phone #
Mailing Address: 4400 HAMILTON DR	
City: EGAN	State: MN Zip Code: 55123

County	Co. Permit #	Notification #	Completed
Barron			09-30-2001

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
THOMAS J RUTHERFORD	4719	

Address: 2795 23 1/2 ST PO BOX 6
BRILL WI 54818

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.6

3. Well serves 1 # of CAMPER
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of CEDAR LK

Fire # (if avail.)

Street Address or Road Name and Number
28 1/8 ST

Subdivision Name	Lot #	Block #
LOCH LOMAN #3	4-13-	

Latitude / Longitude in Decimal Degree (DD) °N °W

Method Code

NE SW or Govt Lot #	Section	Township	Range
	14	36 N	10 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	69

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y	-	BROWN CAVING & GRAVEL	Surface	18
-	-	C	G	CLAY LAYERS GRAVEL	18	26
R	-	-	U	REDISH MUCK	26	30
T	N	S	-	BROWN FINE SAND	30	69

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	IPSCO ASTM A53B 10.79 237	Surface	66
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	WELDED STAINELSS #10 SLOTTED	66	69

7. Grout or Other Sealing Material

Method BNTONITE MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
36 ft. below ground surface

10. Pump Test
Pumping level 55 ft. below surface
Pumping at 12 GP for 12 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
WERE NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TR		10-01-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Building Sanitary		35	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 03-14-2002 Updated On: 03-14-2002 Review Status: