Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QJ674

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ZURN, TREVOR			Phone #: (715)357-6506
Mailing Address: 766 14TH AVE			
City: ALMENA	State: WI	Zip Code: 54805	
County: Barron	Co. Permit #:	Notification #:	Completed: 09-28-2001

Well Constructor (Business Name): THOMAS J RUTHERFORD	Lic. #: 4719	Facility ID # (Public Wells):	
Address: 2795 23 1/2 ST PO BOX 6 BRILL WI 54818		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	

3. Well serves 1 # of NONE
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of CLINTON

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

NE SW or Govt Lot #	Section: 20	Township: 34 N	Range: 13 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	76

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	-	BROWN CAVING SAND	Surface	12
-	-	Y	G	SAND GRAVEL ROCKS	12	28
R	-	P	-	HARDPAN REDISH	28	38
T	N	S	-	BROWN FINE SAND	38	76

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	IPSCO ASTMA53B 1079 237 WELDED	Surface	73
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	STAINELSS #10 SLOTTED	73	76

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
14 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 12 GP for 36 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
WERE NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TR		10-01-2001
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	80
Building Overhang		6

Type	Qualifier	Distance
Sewer - Building Sanitary		20
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 03-14-2002 Updated On: 03-14-2002 Review Status: