

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QJ675		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner DEWITZ, TOM					Phone #		1. Well Location Fire # (if avail.) Town of EDGEWATER Street Address or Road Name and Number					
Mailing Address 123 E HIGH ST												
City CALEDONIA			State MN		Zip Code 55921		Subdivision Name Lot # Block #					
County Sawyer		Co. Permit #		Notification #		Completed 07-02-2001						
Well Constructor (Business Name)			Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
THOMAS J RUTHERFORD			4719				°N °W					
Address 2795 23 1/2 ST PO BOX 6 BRILL WI 54818			Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW NW Section Township Range		or Govt Lot #			
							20 37 N 9 W					
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
				0.8								
3. Well serves 1 # of NONE Private, potable Heat Exchange ___ # of drillholes			Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)		
4		Surface		49		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- Q S G SAND CAVING LARGE ROCK GRAVEL Surface 24 T N S - BROWN FINE SAND 24 49		
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 24 ft. below ground surface		
4		IPSCO ASTM A53B 10 79 237				Surface		46		10. Pump Test Pumping level 40 ft. below surface Pumping at 12 GP M for 12 Hrs. Pumping Method ?		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes		
3		STAINLESS #12 SLOTTED WELDED				46		49				
7. Grout or Other Sealing Material												
Method BENTONITE MOUNDED												
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? WERE NONE			
			Surface									
13. Constructor / Supervisory Driller Lic # Date Signed TR Drill Rig Operator Lic or Reg # Date Signed												

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		155	Shoreline/Pool		200
Building Overhang		40	Sewer - Building Sanitary		38
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-01-2002

Updated On: 03-01-2002

Review Status: