Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: QM654

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TODD, RICHARD		Phone #: (608)787-5454
Mailing Address: 1354 THOMPSON ST		
City: LA CROSSE	State: WI	Zip Code: 54601

County	Co. Permit #	Notification #	Completed
Vernon			05-02-2002

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
PAUL H WEBSTER	156	

Address: 6608 PRUNE LAKE RD
RHINELANDER WI 54501-9173

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		1

3. Well serves # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of HAMBURG
Street Address or Road Name and Number

Fire # (if avail.)

Subdivision Name	Lot #	Block #
VALLEY CT		

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

SE NE or Govt Lot #	Section	Township	Range
	23	14 N	6 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	106
6	106	140

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Yes — Temp. Outer Casing 10in. dia
Yes — Removed? 6depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	20
-	S	N	-	SOFT SANDSTONE	20	90
T	H	N	-	LT BROWN SANDSTONE (HARD)	90	120
I	-	N	-	WHITE SANDSTONE	120	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PLAIN END STEEL WELDED COOPERWELD ASTM A53B CASING 18.97 LBS/FT .280 WALL	Surface	106
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	DRIVE SHOE		

7. Grout or Other Sealing Material

Method: PRESSURE GROUTED W 1IN TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	106	50

9. Static Water Level
34 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 25 GP for 1 Hrs.
Pumping Method ?

11. Well Is
2 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RCK		05-02-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 06-25-2002 Updated On: 06-25-2002 Review Status: