

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QN019		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SADEK, WILL						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 4644 GONYAWATHA TRL						Town of WEST POINT													
City MONONA						State WI		Zip Code 53716											
County Columbia		Co. Permit #		Notification #		Completed 10-07-2001		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) BRAD WEBSTER & SONS DRILLING				Lic. # 6574		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.3602 °N -89.6347 °W									
Address N2323 PINE HOLLOW RD POYNETTE WI 53955				Well Plan Approval #		SE NW		Section 11		Township 10 N		Method Code GCD013							
				Approval Date (mm-dd-yyyy)		Range 7 E													
Hicap Permanent Well #		Common Well #		Specific Capacity 1		2. Well Type Replacement				of previous unique well # constructed in									
3. Well serves 1 # of Private, potable				Hicap Well ? No		Reason for replaced or reconstructed well ?													
Heat Exchange ___ # of drillholes				Hicap Property ? No		Hicap Potable ?				Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		79		Rotary - Mud Circulation				- - C S		SANDY CLAY		Surface		23			
						<u>Yes</u> Rotary - Air		<u>Yes</u>		- - Y -		SAND & GRAVEL		23		63			
						Rotary - Air & Foam				- - S -		CLEAN SAND		63		79			
						Drill-Through Casing Hammer													
						Reverse Rotary													
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface				20 in. above grade					
6		SAWHILL A52B PE .280 WALL 5IN 5FT RISER & K PACKER				Surface		75		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 42 ft. below surface				Disinfected ? Yes					
5		STAINLESS STEEL JOHNSON 15				70		79		Pumping at 12 GP M for 4 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method MOUNDED BENTONITE												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
BENTONITE				Surface				2 S		BW						10-09-2001			
										Drill Rig Operator				Lic or Reg #		Date Signed			
										RW						10-01-2001			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Landfill	>	1200
Building Overhang		11	Sewer - Building Sanitary		45
Shoreline/Pool		135	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 11-13-2001

Updated On: 12-23-2020

Review Status: