Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QN019

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SADEK, WILL	Phone #
Mailing Address: 4644 GONYAWATHA TRL	
City: MONONA	State: WI — Zip Code: 53716
County: Columbia	Co. Permit #	Notification #	Completed: 10-07-2001

1. Well Location

Town of WEST POINT

Fire # (if avail.)

Street Address or Road Name and Number: 2365 PLEASANT VIEW CIR

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
BRAD WEBSTER & SONS DRILLING	6574	

Latitude / Longitude in Decimal Degree (DD): 43.3602 °N -89.6347 °W — Method Code: GCD013

Well Plan Approval #

SE	NW	Section	Township	Range
or Govt Lot #		11	10 N	7 E

Address: N2323 PINE HOLLOW RD, POYNETTE WI 53955

Approval Date (mm-dd-yyyy)

2. Well Type Replacement

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		1

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	79

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	S	SANDY CLAY	Surface	23
-	-	Y	-	SAND & GRAVEL	23	63
-	-	S	-	CLEAN SAND	63	79

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL A52B PE .280 WALL 5IN 5FT RISER & K PACKER	Surface	75
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL JOHNSON 15	70	79

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 42 ft. below surface

Pumping at 12 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: MOUNDED BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface		2 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BW		10-09-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RW		10-01-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75
Building Overhang		11
Shoreline/Pool		135
Landfill	>	1200
Sewer - Building Sanitary		45
Septic or Holding, or POWTS Tank		65

Comment:

Created On: 11-13-2001 Updated On: 12-23-2020 Review Status: