

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QN025		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MARSHALL, CHRIS						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 452 VALLEY VIEW RD						Town of BRISTOL													
City POYNETTE						State WI		Zip Code 53955				Street Address or Road Name and Number 2808 COUNTRY DR							
County Dane		Co. Permit # 18532		Notification #		Completed 10-09-2001		Subdivision Name BROOKS RDG				Lot # 18 Block #							
Well Constructor (Business Name) BRAD WEBSTER & SONS DRILLING				Lic. # 6574		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2107 °N -89.2182 °W				Method Code GCD013					
Address N2323 PINE HOLLOW RD POYNETTE WI 53955				Well Plan Approval #		SE SW		Section 29		Township 9 N		Range 11 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 3		2. Well Type New Well						of previous unique well # constructed in							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Reason for replaced or reconstructed well ?													
Heat Exchange ___ # of drillholes				Hicap Property ? No															
				Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
8.8 Surface 180											- - C -		CLAY		Surface 10				
6 180 245			Rotary - Mud Circulation								- - L -		LIMESTONE		10 29				
			Yes Rotary - Air No								- - N -		SANDSTONE		29 245				
			No Rotary - Air & Foam Yes																
			Drill-Through Casing Hammer																
			Reverse Rotary																
			Cable-tool Bit ___ in. dia...																
			Dual Rotary																
			Yes Temp. Outer Casing 10in. dia																
			Yes Removed? 10depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		91 ft. below ground surface				20 in. above grade					
6		SAWHILL A53B PE .280 VOL				Surface		180		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 95 ft. below surface				Disinfected ? Yes					
										Pumping at 12 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method PRESSURE TREMIE																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No					
NEAT CEMENT				Surface		180		50 S		NONE ON PROPERTY									
13. Constructor / Supervisory Driller														Lic #		Date Signed			
BW																10-10-2001			
Drill Rig Operator														Lic or Reg #		Date Signed			
RW																10-10-2001			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	90	Landfill	>	1200
Building Overhang		45	Sewer - Building Sanitary		60
Foundation Drain to Clearwater		45	Septic or Holding, or POWTS Tank	>	70

Comment:

Created On: 11-13-2001

Updated On: 12-11-2019

Review Status: