

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QN029		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KOT, TOM & SHARON						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 6718 SAM HL						Town of BRISTOL													
City SUN PRAIRIE						State WI		Zip Code 53950				Street Address or Road Name and Number 6718 SAM HL							
County Dane		Co. Permit # 19661		Notification #		Completed 10-11-2001		Subdivision Name HOMESTEAD ESTS				Lot # 8 Block #							
Well Constructor (Business Name) BRAD WEBSTER & SONS DRILLING				Lic. # 6574		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2154 °N -89.2215 °W				Method Code GCD013					
Address N2323 PINE HOLLOW RD POYNETTE WI 53955				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 29 9 N 11 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 1.2															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.8		Surface		180						T - C -		BROWN CLAY		Surface		7			
6		180		201		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 7depth ft. (If NO explain on back side)				- - L -		LIMESTONE		7		47			
										- S N -		SOFT SANDSTONE		47		75			
										- H N -		FIRM SANDSTONE		75		201			
6. Casing, Liner, Screen												8. Geology							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 91 ft. below ground surface				11. Well Is 20 in. above grade					
6		SAWHILL A53B PE .280 WALL				Surface		180		10. Pump Test Pumping level 101 ft. below surface Pumping at 12 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material Method PRESSURE TREMIE												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NONE ON PROPERTY							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT				Surface		180		60 S		BW						10-15-2001			
										Drill Rig Operator				Lic or Reg #		Date Signed			
										TW						10-11-2001			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	65	Landfill	>	1200
Building Overhang		13	Sewer - Building Sanitary		45
Foundation Drain to Sewer		40	Septic or Holding, or POWTS Tank	>	35

Comment:

Created On: 11-13-2001

Updated On: 12-11-2019

Review Status: