

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QN123		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DUEHOLM, CARTER						Phone # (715)857-5141		1. Well Location				Fire # (if avail.)			
Mailing Address 2033 100TH ST CO RD						Town of GEORGETOWN						2033			
City LUCK						State WI		Zip Code 54853				Street Address or Road Name and Number 2033 100TH ST C RD I			
County Polk		Co. Permit #		Notification #		Completed 12-17-2001		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) BRIAN COX				Lic. # 6644		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address 1653 210TH AVE MILLTOWN WI 54858				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW SE Section Township Range or Govt Lot # 20 35 N 16 W		2. Well Type New Well					
Hicap Permanent Well #				Common Well #		Specific Capacity 1.1		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of BARN						Hicap Well ? No		Construction Type Drilled							
Private, potable						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock						
4		Surface		43											
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit ___ in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)						
- - I -			TOPSOIL			Surface			2						
- - S -			SAND			2			43						
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4		CASING STEEL IPSCO WELDED ASTM-A53B/ASME HT 705326				Surface		39							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
4		JOHNSON SS 12 SLOT				38		43							
7. Grout or Other Sealing Material															
Method MOUNDED BENTONITE															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
				Surface											
9. Static Water Level															
12 ft. below ground surface															
10. Pump Test															
Pumping level 30 ft. below surface															
Pumping at 20 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
BC										12-17-2001					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Shoreline/Pool		500	Animal Barn Pen		50
			Animal Yard - Include Hutches		53

Comment:

Created On: 01-31-2002

Updated On: 01-31-2002

Review Status: