Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QN123

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DUEHOLM, CARTER			Phone #: (715)857-5141
Mailing Address: 2033 100TH ST CO RD			
City: LUCK	State: WI	Zip Code: 54853	
County: Polk	Co. Permit #:	Notification #:	Completed: 12-17-2001

Well Constructor (Business Name): BRIAN COX	Lic. #: 6644	Facility ID # (Public Wells):	
Address: 1653 210TH AVE MILLTOWN WI 54858		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.1	

1. Well Location

Town of GEORGETOWN					Fire # (if avail.): 2033
Street Address or Road Name and Number: 2033 100TH ST C RD I					
Subdivision Name			Lot #		Block #
Latitude / Longitude in Decimal Degree (DD): °N °W					Method Code
NW SE or Govt Lot #	Section: 20	Township: 35 N	Range: 16 W		

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of BARN
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	43

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / No — Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	2
-	-	S	-	SAND	2	43

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	CASING STEEL IPSCO WELDED ASTM-A53B/ASME HT 705326	Surface	39
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	JOHNSON SS 12 SLOT	38	43

7. Grout or Other Sealing Material

Method MOUNDED BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BC		12-17-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Shoreline/Pool		500	Animal Barn Pen		50
			Animal Yard - Include Hutches		53

Comment:

Created On: 01-31-2002 Updated On: 01-31-2002 Review Status: