Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QN128

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BOUER, DALE	Phone #
Mailing Address: 24819 LARREBEE SUBDI	
City: WEBSTER	State: WI — Zip Code: 54893
County: Burnett	Co. Permit #	Notification #	Completed: 01-03-2002
Well Constructor (Business Name): BRIAN COX	Lic #: 6644	Facility ID # (Public Wells)
Address: 1653 210TH AVE MILLTOWN WI 54858	Well Plan Approval #	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.8

1. Well Location

Town of SAND LAKE				Fire # (if avail.): 24819
Street Address or Road Name and Number: 24819 LARREBEE SUBDIVISION RD				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code
SW or Govt Lot #	SW	Section: 32	Township: 39 N	Range: 15 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	92

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 4in. dia... No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	8
-	-	C	-	CLAY	8	43
-	-	S	M	SILTY SAND	43	61
-	-	Z	-	CLAY & GRAVEL	61	87
-	A	S	-	SAND COARSE	87	92

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	CASING STEEL WELDED IPSCO ASTM A53B/ASME HT 705326	Surface	88
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	JOHNSON SS 10 SLOT	87	92

7. Grout or Other Sealing Material

Method MOUNDED BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BC		01-03-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		200
Building Drain - Sanitary		10
Building Overhang		8
Foundation Drain to Sewer		10

Type	Qualifier	Distance
Shoreline/Pool		300
Wastewater Sump		40
Sewer - Building Sanitary		10
Septic or Holding, or POWTS Tank		40

Comment:

Created On: 01-31-2002 Updated On: 01-31-2002 Review Status: