Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QN981

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: REHDER, NORBERT	Phone #: (715)395-1340
Mailing Address: 1400 BILMAR AVE	
City: NEW RICHMOND	State: WI — Zip Code: 54017
County: Burnett	Co. Permit #: — Notification #: — Completed: 06-24-2003
Well Constructor (Business Name): GARY BEECROFT	Lic. #: 137 — Facility ID # (Public Wells):
Address: GARY BEECROFT WELL DRLG & WATER SYS, SIREN WI 54872-9604	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.3

1. Well Location
Town of UNION
Fire # (if avail.):
Street Address or Road Name and Number: RIDGE RD
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SE	SE	Section	Township	Range
or Govt Lot #		30	40 N	17 W

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	151.42

Upper Enlarged Drillhole: Yes
Lower Open Bedrock: No
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	EAGLE SDR 17 PVC	Surface	151.42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
VOLCLAY	Surface		

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	41
-	-	S	-	SAND	41	55
-	-	C	-	CLAY	55	130
-	-	P	-	HARDPAN	130	149
-	A	G	-	COARSE GRAVEL	149	151.42
		B		TRAP ROCK	151.42	151.42

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 50 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GB		07-08-2003
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		93

Type	Qualifier	Distance
Building Overhang		27
Septic or Holding, or POWTS Tank		81

Comment:

Created On: 08-21-2003 Updated On: 08-21-2003 Review Status: