

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QN983		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner BRUNER, TIM					Phone # (763)767-3997		1. Well Location				Fire # (if avail.)			
Mailing Address 3148 142ND AVE NE							Town of UNION				27251			
City HAM LAKE					State MN		Zip Code 55304							
County Burnett		Co. Permit #		Notification #		Completed 06-30-2003		Street Address or Road Name and Number 27251 CO RD FF						
Well Constructor (Business Name) GARY BEECROFT					Lic. # 137		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address GARY BEECROFT WELL DRLG & WATER SYS SIREN WI 54872-9604					Well Plan Approval #		SW SE Section Township Range or Govt Lot # 35 40 N 17 W							
Hicap Permanent Well #					Common Well #		Specific Capacity 0.4		2. Well Type New Well of previous unique well # constructed in					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes					Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ? NEW HOME							
							Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
8.75		Surface		72.25		Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
-	-	S	-	SAND		Surface		11						
-	-	C	-	CLAY		11		16						
-	-	S	-	SAND		16		41						
-	-	Y	-	SAND & GRAVEL		41		72.25						
		C		CLAY		72.25		72.25						
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
5		EAGLE SDR 17 PVC				Surface		68						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
4		15 SLOT S. STEEL SCREEN				68		72.25						
7. Grout or Other Sealing Material														
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement VOLCLAY Surface														
9. Static Water Level 52 ft. below ground surface														
10. Pump Test Pumping level 65 ft. below surface Pumping at 5 GP M for 2 Hrs. Pumping Method ?														
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
GB								07-08-2003						
Drill Rig Operator						Lic or Reg #		Date Signed						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		157	Building Overhang		45
			Septic or Holding, or POWTS Tank		132

Comment:

Created On: 07-30-2003

Updated On: 07-30-2003

Review Status: