Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QO649

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DUDA, SCOTT			Phone #: (715)238-7108
Mailing Address: W246 WILLARD RD			
City: SPENCER	State: WI	Zip Code: 54479	
County: Clark	Co. Permit #:	Notification #:	Completed: 01-03-2002

1. Well Location

Town of SHERMAN

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
BRIAN HEEG	355	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

Well Plan Approval #

SW	SE	Section	Township	Range
or Govt Lot #		12	26 N	1 E

Address: 5069 E CTY F
AUBURNDALE WI 54412

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	16
6	16	180

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	C	-	CLAY	Surface	16
Y	Q	S	-	SAND	16	38
T	Q	Z	S	CLAY, SAND & GRAVEL LAYERS	38	90
R	H	Q	-	GRANITE	90	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ST STEEL ASTM A53B SAWHILL USA WELDED JOINT	Surface	90
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 170 ft. below surface

Pumping at 8 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD & CUTTINGS	Surface	16	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
BH		01-03-2002
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 03-01-2002 Updated On: 03-01-2002 Review Status: