

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QO658		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner VOGT, ROBERT Phone # (262)657-5472						1. Well Location						Fire # (if avail.)					
Mailing Address 5712 34TH AVE						Town of BROCKWAY											
City KENOSHA State WI Zip Code 53144						Street Address or Road Name and Number N6601 HIDEAWAY RD											
County Jackson		Co. Permit #		Notification #		Completed 04-11-2002		Subdivision Name				Lot #	Block #				
Well Constructor (Business Name) BRIAN HEEG				Lic. # 355	Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 44.3103 °N -90.8181 °W				Method Code GCD013					
Address 5069 E CTY F AUBURNDALE WI 54412				Well Plan Approval #			SW	SW	Section 12	Township 21 N	Range 4 W						
				Approval Date (mm-dd-yyyy)			or Govt Lot #										
Hicap Permanent Well #		Common Well #		Specific Capacity 1.2		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
3. Well serves 1 # of TRAILER Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)			
6	Surface	53	Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								I	Q	S	-	SAND	Surface	53
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)	32 ft. below ground surface				12 in. above grade						
6	ST STEEL ASTM A53B SAWHILL USA WELDED JOINT				Surface	50	10. Pump Test				Developed ? Yes						
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)	Pumping level 45 ft. below surface				Disinfected ? Yes						
5	12 SLOT STAINLESS				50	53	Pumping at 15 GP for 1 Hrs.				Capped ? Yes						
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method												Filled & Sealed Well(s) as needed? NONE					
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement													
		Surface															
13. Constructor / Supervisory Driller												Lic #	Date Signed				
BH													04-11-2002				
Drill Rig Operator												Lic or Reg #	Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		20
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 05-14-2002

Updated On: 05-01-2020

Review Status: