Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QP092

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JENKINS, RONALD			Phone #
Mailing Address: W329 S4229 HWY E			
City: WAUKESHA	State: WI	Zip Code: 53127	
County: Waukesha	Co. Permit #	Notification #	Completed: 02-22-2003

Well Constructor (Business Name): ARTESIAN WELL & PUMP CO	Lic #: 6640	Facility ID # (Public Wells)	
Address: 103 OAKRIDGE DR NORTH PRAIRIE WI 53153-0094		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.2	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of GENESEE

Fire # (if avail.)

Street Address or Road Name and Number: W329 S4229 HWY E

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
42.9689 °N	-88.405 °W			GCD013
SW NW or Govt Lot #	Section: 19	Township: 6 N	Range: 18 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	385

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	58
-	-	L	-	LIMESTONE	58	145
-	-	H	-	SHALE	145	320
-	-	H	L	SHALE WITH LIMESTONE	320	385

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAW HILL USA STD ERW A53-90 GR B BLACK PLAIN END 6.625 ODX .280 WALL	Surface	58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
120 ft. below ground surface

10. Pump Test
Pumping level 180 ft. below surface
Pumping at 10 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MESH BENTONITE & CUTTINGS	Surface	58	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RLD		02-22-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85

Type	Qualifier	Distance
Sewer - Building Sanitary		30
Septic or Holding, or POWTS Tank		65

Comment:

Created On: 01-19-2006 Updated On: 07-12-2019 Review Status: