Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QP104

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RYGIEWICZ, FRED	Phone #: (262)835-1170
Mailing Address: 2607 76TH ST	
City: FRANKSVILLE	State: WI Zip Code: 53126
County: Racine	Co. Permit #:	Notification #:	Completed: 05-26-2002
Well Constructor (Business Name): JOHN D KRIZAN JR	Lic. #: 571	Facility ID # (Public Wells):
Address: KRIZAN WELL DRLG & PUMP, UNION GROVE WI 53182-9659	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0

1. Well Location

Town of RAYMOND

Fire # (if avail.):

Street Address or Road Name and Number: 2607 76TH ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 42.7987 °N -88.0128 °W

Method Code: GCD013

NE or Govt Lot #	NE	Section	Township	Range
		21	4 N	21 E

2. Well Type Reconstruction

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: OTHER WELL IS SLOW PRODUC

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	264

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	-	C	-	YELLOW CLAY	Surface	10
U	-	C	-	BLUE CLAY	10	60
U	-	C	G	STONEY BLUE CLAY	60	98
-	-	G	-	GRAVEL	98	102
U	-	C	-	BLUE CLAY	102	120
-	-	P	-	HARD PAN	120	142
-	-	L	-	LIME ROCK	142	264

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL USA 10-01 ASTM A53B 6.625 X 280 EL 20 HEAT #65659 WELDED	Surface	142
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

27 ft. below ground surface

10. Pump Test

Pumping level 240 ft. below surface

Pumping at 3 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

17 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR #8 MESH	Surface	142	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

STILL IN USE

13. Constructor / Supervisory Driller	Lic #	Date Signed
KK		05-26-2002
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		39

Comment:

Created On: 11-20-2003 Updated On: 10-15-2026 Review Status: