

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QP104		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner RYGIEWICZ, FRED						Phone # (262)835-1170		1. Well Location				Fire # (if avail.)					
Mailing Address 2607 76TH ST						Town of RAYMOND											
City FRANKSVILLE						State WI		Zip Code 53126									
County Racine		Co. Permit #		Notification #		Completed 05-26-2002		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) JOHN D KRIZAN JR				Lic. # 571		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.7987 °N -88.0128 °W							
Address KRIZAN WELL DRLG & PUMP UNION GROVE WI 53182-9659				Well Plan Approval #		NE NE		Section 21		Township 4 N		Method Code GCD013					
				Approval Date (mm-dd-yyyy)		or Govt Lot #		Range 21 E									
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type Reconstruction											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in									
						Hicap Property ? No		Reason for replaced or reconstructed well ?									
4. Potential Contamination Sources - ON REVERSE SIDE						Hicap Potable ?		OTHER WELL IS SLOW PRODUC									
								Construction Type Drilled									
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) 6		From (ft.) Surface		To (ft.) 264		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
						Rotary - Mud Circulation				Y - C -		YELLOW CLAY		Surface 10			
						Rotary - Air				U - C -		BLUE CLAY		10 60			
						Rotary - Air & Foam				U - C G		STONEY BLUE CLAY		60 98			
						Yes Drill-Through Casing Hammer				- - G -		GRAVEL		98 102			
						Reverse Rotary				U - C -		BLUE CLAY		102 120			
						Cable-tool Bit ___ in. dia...				- - P -		HARD PAN		120 142			
						Dual Rotary				- - L -		LIME ROCK		142 264			
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.) 6		Material, Weight, Specification SAWHILL USA 10-01 ASTM A53B 6.625 X 280 EL 20 HEAT #65659 WELDED				From (ft.) Surface		To (ft.) 142		27 ft. below ground surface		17 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes					
										Pumping level 240 ft. below surface		Disinfected ? Yes					
										Pumping at 3 GP M for 24 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method MOUNDED												Filled & Sealed Well(s) as needed? No STILL IN USE					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
GRANULAR #8 MESH		Surface		142													
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												KK				05-26-2002	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		39

Comment:

Created On: 11-20-2003

Updated On: 06-28-2019

Review Status: