Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QP106

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BISSONETTE, MICHAEL	Phone #: (262)642-2928
Mailing Address: W2240 BEULAH HEIGHTS	
City: EAST TROY	State: WI — Zip Code: 53120
County: Racine	Co. Permit #:
Notification #	Completed: 06-09-2002
Well Constructor (Business Name): JOHN D KRIZAN JR	Lic. #: 571
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 23900 W OVERSON RD UNION GROVE WI 53182-9659	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 2	

1. Well Location

Town of DOVER

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name: DOVER DEER MDWS	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) — °N °W

Method Code

SE SW or Govt Lot #	Section: 26	Township: 3 N	Range: 20 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NEW CONST.

Construction Type: Drilled

3. Well serves 2 # of HOMES

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	98

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	-	C	-	YELLOW CLAY	Surface	10
U	-	C	-	BLUE CLAY	10	30
U	-	C	G	STONEY BLUE CLAY	30	96
-	-	Y	-	SAND & GRAVEL	96	98

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	TEXAS TUBULAR 6.625 ASTM A53B 18.99# HEAT 38627 WELDED	Surface	98
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 20 GP M for 12 Hrs.

Pumping Method ?

11. Well Is

30 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MESH BENTONITE	Surface	98	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE THERE

13. Constructor / Supervisory Driller	Lic #	Date Signed
KK		06-12-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		19	Downspout/Yard Hydrant		19

Comment:

Created On: 02-07-2003 Updated On: 02-07-2003 Review Status: