

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QP106		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BISSONETTE, MICHAEL						Phone # (262)642-2928		1. Well Location				Fire # (if avail.)							
Mailing Address W2240 BEULAH HEIGHTS						Town of DOVER													
City EAST TROY						State WI		Zip Code 53120											
County Racine		Co. Permit #		Notification #		Completed 06-09-2002		Subdivision Name DOVER DEER MDWS				Lot # Block #							
Well Constructor (Business Name) JOHN D KRIZAN JR				Lic. # 571		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 23900 W OVERSON RD UNION GROVE WI 53182-9659				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 26 3 N 20 E		2. Well Type New Well of previous unique well # constructed in											
Hicap Permanent Well #		Common Well #		Specific Capacity 2		Reason for replaced or reconstructed well ? NEW CONST.													
3. Well serves 2 # of HOMES Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		98						Y - C -		YELLOW CLAY		Surface		10			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				U - C -		BLUE CLAY		10		30			
										U - C G		STONEY BLUE CLAY		30		96			
										- - Y -		SAND & GRAVEL		96		98			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				30 in. above grade					
6		TEXAS TUBULAR 6.625 ASTM A53B 18.99# HEAT 38627 WELDED				Surface		98		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 50 ft. below surface Pumping at 20 GP M for 12 Hrs. Pumping Method ?									
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No NONE THERE									
#8 MESH BENTONITE				Surface		98													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												KK						06-12-2002	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		19	Downspout/Yard Hydrant		19

Comment:

Created On: 02-07-2003

Updated On: 02-07-2003

Review Status: