

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QP839		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																			
Property Owner ANDERSON, VICKY						Phone # (920)897-2009		1. Well Location				Fire # (if avail.)																	
Mailing Address PO BOX 155						Town of WABENO																							
City POUND						State WI		Zip Code 54161																					
County Forest		Co. Permit #		Notification #		Completed 10-30-2001		Subdivision Name				Lot # Block #																	
Well Constructor (Business Name) T & T WELL DRILLING				Lic. # 6571		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.39152 °N -88.62569 °W				Method Code GPS008															
Address 15271 HWY 32 LAKEWOOD WI 54138				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 33 34 N 15 E				2. Well Type New Well																			
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in																			
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		Reason for replaced or reconstructed well ?																							
3. Well serves 1 # of				Hicap Well ? No																									
Private, potable				Hicap Property ? No																									
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled																							
4. Potential Contamination Sources - ON REVERSE SIDE																													
5. Drillhole Dimensions and Construction Method												8. Geology																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)											
10		Surface		50		Yes Rotary - Mud Circulation				No		- - Y C		SAND-GRAVEL-CLAY		Surface		5											
6		50		63		Rotary - Air						- - Y C		SAND-GRAVEL-CLAY-BOULDERS		5		45											
						Rotary - Air & Foam						- - X -		SAND-CLAY		45		52											
						Drill-Through Casing Hammer						- - Y -		SAND-GRAVEL		52		63											
						Reverse Rotary																							
						Cable-tool Bit ___ in. dia...																							
						Dual Rotary																							
						Temp. Outer Casing ___ in. dia																							
						Removed? ___ depth ft. (If NO explain on back side)																							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				12 in. above grade															
6		ASTM A-53 GR. B SAWHILL WELDED 18.97 PER. FT.				Surface		60		10. Pump Test				Developed ? Yes															
										Pumping level 46 ft. below surface				Disinfected ? Yes															
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 15 GP M for 4 Hrs.				Capped ? Yes															
4		STAINLESS #12				60		63		Pumping Method ?																			
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?																	
Method												Filled & Sealed Well(s) as needed?																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller														Lic #		Date Signed			
DRILLING MUD				Surface		50				AT																11-25-2001			
												Drill Rig Operator				Lic or Reg #		Date Signed											
												MB						11-25-2001											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Septic or Holding, or POWTS Tank		25

Comment:

Created On: 01-28-2002

Updated On: 08-23-2022

Review Status: