Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QP839

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ANDERSON, VICKY	Phone #: (920)897-2009
Mailing Address: PO BOX 155	
City: POUND	State: WI — Zip Code: 54161
County: Forest	Co. Permit #: — Notification #: — Completed: 10-30-2001
Well Constructor (Business Name): T & T WELL DRILLING	Lic. #: 6571 — Facility ID # (Public Wells):
Address: 15271 HWY 32 LAKEWOOD WI 54138	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Town of WABENO

Fire # (if avail.):

Street Address or Road Name and Number: 3910 MAIN ST

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 45.39152 °N -88.62569 °W — Method Code: GPS008

NW or Govt Lot #	NE	Section	Township	Range
		33	34 N	15 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	50
6	50	63

Upper Enlarged Drillhole: Yes

Lower Open Bedrock: No

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	C	SAND-GRAVEL-CLAY	Surface	5
-	-	Y	C	SAND-GRAVEL-CLAY-BOULDERS	5	45
-	-	X	-	SAND-CLAY	45	52
-	-	Y	-	SAND-GRAVEL	52	63

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR. B SAWHILL WELDED 18.97 PER. FT.	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS #12	60	63

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 46 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	50	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
AT		11-25-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MB		11-25-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Septic or Holding, or POWTS Tank		25

Comment:

Created On: 01-28-2002 Updated On: 08-23-2022 Review Status: