Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QP842

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BARTELS, DON			Phone #
Mailing Address: 17097 CLUB HOUSE LN			
City: LAKEWOOD	State: WI	Zip Code: 54138	
County: Oconto	Co. Permit #	Notification #	Completed: 01-10-2002

Well Constructor (Business Name): T & T WELL DRILLING	Lic. #: 6571	Facility ID # (Public Wells)	
Address: 15271 HWY 32 LAKEWOOD WI 54138		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LAKEWOOD

Fire # (if avail.)

Street Address or Road Name and Number: LONG ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

NE	NW	Section	Township	Range
or Govt Lot #		32	33 N	16 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	50
6	50	84

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	G	SAND-GRAVEL & BOULDERS	Surface	20
-	-	Y	-	SAND-GRAVEL	20	30
-	-	Y	G	SAND-GRAVEL-BOULDERS	30	40
-	-	Y	-	SAND-GRAVEL	40	70
-	-	S	-	SAND	70	84

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR.B SAWHILL TUBULAR WELDED JT 18.97#/FT	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS #12	80	84

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	50	

9. Static Water Level
40 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 8 GP for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TH		01-16-2002
Drill Rig Operator	Lic or Reg #	Date Signed
AT		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Sewer - Building Sanitary		12

Comment:

Created On: 03-25-2002 Updated On: 12-18-2003 Review Status: