Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QQ493

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KING, JAMES		Phone #: (262)697-9959
Mailing Address: 7946 47TH AVE		
City: KENOSHA	State: WI	Zip Code: 53142

County	Co. Permit #	Notification #	Completed
Langlade			05-19-2002

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
PHILIP J KOEPPEL	667	

Address: W8060 S PARK RD
ANTIGO WI 54409-8963

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.7

3. Well serves 2 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of UPHAM

Fire # (if avail.)

Street Address or Road Name and Number
W10868 MERLIN ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.3733 °N	-89.1988 °W			GCD013

SW	NW	Section	Township	Range
or Govt Lot #		1	33 N	10 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	74

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	V	C	S	NONCAVING SANDY CLAY	Surface	5
-	Q	Y	-	CAVING SAND & GRAVEL	5	55
-	N	S	U	MUDDY FINE SAND	55	70
G	-	S	-	GRAY SAND	70	74

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	BLACK STEEL A53B 14.62#/FT. .280IN WELDED IPSCO	Surface	70
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	SS JOHNSON TELESCOPE .012	70	74

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		0.5

9. Static Water Level
48 ft. below ground surface

10. Pump Test
Pumping level 62 ft. below surface
Pumping at 10 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
23 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
PK		05-25-2002
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SDD		05-30-2002

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		79
Building Overhang		11

Type	Qualifier	Distance
Sewer - Building Sanitary		45
Septic or Holding, or POWTS Tank		62

Comment:

Created On: 06-28-2002 Updated On: 06-12-2020 Review Status: