

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QQ657		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BRAUN, DAN						Phone # (815)385-8411		1. Well Location				Fire # (if avail.)			
Mailing Address 10037 270TH CT						Town of SALEM									
City SALEM						State WI		Zip Code 53168							
County Kenosha		Co. Permit #		Notification # 22691766		Completed 05-25-2006		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) GROSS E E WELL DRILLING INC				Lic. # 387		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.5262 °N -88.1389 °W				Method Code GCD013	
Address 43320 N HWY 41 ZION IL 60099				Well Plan Approval # Approval Date (mm-dd-yyyy)		SE SW		Section 21		Township 1 N		Range 20 E			
						or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well					
Hicap serves 1 # of Private, potable				Hicap Well ? No		Reason for replaced or reconstructed well ?									
Heat Exchange ___ # of drillholes				Hicap Property ? No		Hicap Potable ?				Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
4		Surface		97											
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
K	-	I	-	BLK SOIL				Surface		2					
Y	-	C	-	YELLOW CLAY				2		9					
U	-	C	-	BLUE CLAY				9		24					
G	-	C	-	GRAY CLAY				24		90					
-	-	Y	-	SAND & GRAVEL				90		97					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4		GALV STEEL 11 LBS PER FT ASTM A-53-B SEALED T & C				Surface		94							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
3.75		TELESCOPING STAINLESS #15				94		97							
7. Grout or Other Sealing Material															
Method GRAVITY															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface		70									
9. Static Water Level															
4 ft. below ground surface															
10. Pump Test															
Pumping level 4 ft. below surface															
Pumping at 15 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
14 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No															
NEW HOME															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
MG										06-09-2006					
Drill Rig Operator								Lic or Reg #		Date Signed					
TW										06-01-2006					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Clearwater Sump		40	Foundation Drain to Clearwater		14
Collector Sewer - San or Storm		90	Sewer - Building Sanitary		35

Comment:

Created On: 07-11-2006

Updated On: 08-23-2019

Review Status: