Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QQ657

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRAUN, DAN			Phone #: (815)385-8411
Mailing Address: 10037 270TH CT			
City: SALEM	State: WI	Zip Code: 53168	
County: Kenosha	Co. Permit #:	Notification #: 22691766	Completed: 05-25-2006

1. Well Location

Town of SALEM

Fire # (if avail.)

Street Address or Road Name and Number: 10037 270TH CT

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
GROSS E E WELL DRILLING INC	387	

Latitude / Longitude in Decimal Degree (DD): 42.5262 °N -88.1389 °W

Method Code: GCD013

Well Plan Approval #:

SE SW or Govt Lot #	Section	Township	Range
	21	1 N	20 E

Address: 43320 N HWY 41, ZION IL 60099

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	97

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	-	I	-	BLK SOIL	Surface	2
Y	-	C	-	YELLOW CLAY	2	9
U	-	C	-	BLUE CLAY	9	24
G	-	C	-	GRAY CLAY	24	90
-	-	Y	-	SAND & GRAVEL	90	97

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	GALV STEEL 11 LBS PER FT ASTM A-53-B SEALED T & C	Surface	94
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.75	TELESCOPING STAINLESS #15	94	97

9. Static Water Level

4 ft. below ground surface

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

10. Pump Test

Pumping level 4 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

7. Grout or Other Sealing Material

Method: GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	70	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NEW HOME

13. Constructor / Supervisory Driller	Lic #	Date Signed
MG		06-09-2006
Drill Rig Operator	Lic or Reg #	Date Signed
TW		06-01-2006

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Clearwater Sump		40	Foundation Drain to Clearwater		14
Collector Sewer - San or Storm		90	Sewer - Building Sanitary		35

Comment:

Created On: 07-11-2006 Updated On: 08-23-2019 Review Status: