

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QR423		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A								
Property Owner SOCKNESS, LEONARD						Phone # (715)644-2609		1. Well Location				Fire # (if avail.)						
Mailing Address N15048 FERNWAL AVE						Town of THORP						Street Address or Road Name and Number N15048 FERNWAL AVE						
City STANLEY		State WI		Zip Code 54768		Subdivision Name				Lot #		Block #						
County Clark		Co. Permit #		Notification #		Completed 11-09-2002		Latitude / Longitude in Decimal Degree (DD) 44.9646 °N -90.882 °W				Method Code GCD013						
Well Constructor (Business Name) JEFF HATFIELD				Lic. # 5201		Facility ID # (Public Wells)		NW SW Section Township Range or Govt Lot # 28 29 N 4 W		2. Well Type New Well VE220 replaces this well of previous unique well # constructed in								
Address 9180 CO HWY G STANLEY WI 54768-6014				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ?										
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		Construction Type Drilled												
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?												
4. Potential Contamination Sources - ON REVERSE SIDE																		
5. Drillhole Dimensions and Construction Method																		
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock															
10 Surface 20			Rotary - Mud Circulation															
6 20 55			Rotary - Air															
			Rotary - Air & Foam															
			Drill-Through Casing Hammer															
			Reverse Rotary															
			Yes Cable-tool Bit 10in. dia... No															
			Dual Rotary															
			Temp. Outer Casing ___ in. dia															
			Removed? ___ depth ft. (If NO explain on back side)															
8. Geology																		
Dia. (in.)			From (ft.)			To (ft.)			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)		To (ft.)	
10			Surface			20			- - C -			CLAY			Surface		41	
6			20			55			- - N C			SOAP ROCK (RESIDUE CLAY)			41		55	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is		
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		7 ft. below ground surface				12 in. above grade				
6		STD BLACK STEEL WELDED PLAIN END .280 WALL 19.49 A.S.T.M. A-53 SAWHILL				Surface		47		10. Pump Test				Developed ? Yes				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 45 ft. below surface				Disinfected ? Yes				
										Pumping at 2 GP M for 24 Hrs.				Capped ? Yes				
										Pumping Method ?								
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?						
Method												Filled & Sealed Well(s) as needed? Yes						
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		HE HAS A DUG WELL AND HE WANTS										
CLAY SLURRY		Surface		20														
13. Constructor / Supervisory Driller												Lic #		Date Signed				
JJH														12-18-2002				
Drill Rig Operator												Lic or Reg #		Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		40	Nonconforming Pit or Alcove		55
Downspout/Yard Hydrant		15	Privy		120
			Septic or Holding, or POWTS Tank		100

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	07/15/2010	CETCO MEDIUM SIZED BENTONITE CHIPS 0-56' 17 SACKS USED	UNUSED

Created On: 02-06-2003

Updated On: 05-18-2020

Review Status: