Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QR423

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SOCKNESS, LEONARD	Phone #: (715)644-2609
Mailing Address: N15048 FERNWAL AVE	
City: STANLEY	State: WI — Zip Code: 54768
County: Clark	Co. Permit #:
Notification #	Completed: 11-09-2002
Well Constructor (Business Name): JEFF HATFIELD	Lic. #: 5201
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 9180 CO HWY G STANLEY WI 54768-6014	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.1	

1. Well Location

Town of THORP

Fire # (if avail.)

Street Address or Road Name and Number: N15048 FERNWAL AVE

Subdivision Name	Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.9646 °N -90.882 °W		Method Code: GCD013

NW	SW	Section	Township	Range
or Govt Lot #		28	29 N	4 W

2. Well Type New Well — VE220 replaces this well of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	55

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	41
-	-	N	C	SOAP ROCK (RESIDUE CLAY)	41	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD BLACK STEEL WELDED PLAIN END .280 WALL 19.49 A.S.T.M. A-53 SAWHILL	Surface	47
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

7 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 2 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

HE HAS A DUG WELL AND HE WANTS

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJH		12-18-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		40	Nonconforming Pit or Alcove		55
Downspout/Yard Hydrant		15	Privy		120
			Septic or Holding, or POWTS Tank		100

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	07/15/2010	CETCO MEDIUM SIZED BENTONITE CHIPS 0-56' 17 SACKS USED	UNUSED

Created On: 02-06-2003 Updated On: 05-18-2020 Review Status: