

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QR616		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner STULZMAN, MARVIN						Phone #		1. Well Location				Fire # (if avail.)													
Mailing Address 11723 KLANG DR								Town of WESTFORD																	
City CAZENOVIA						State WI		Zip Code 53924																	
County Richland		Co. Permit #		Notification #		Completed 09-05-2002		Subdivision Name				Lot #		Block #											
Well Constructor (Business Name) AAA QUAL WD/DIV WE TRKING HILLSBORO				Lic. # 6723		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code													
Address S1595 SCENIC DR HILLSBORO WI 54634				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 11 12 N 2 E		2. Well Type New Well of previous unique well # constructed in																	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ? FIRST ON SITE																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled																			
4. Potential Contamination Sources - ON REVERSE SIDE																									
5. Drillhole Dimensions and Construction Method														8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
8.75		Surface		84		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> <u>Yes</u> Rotary - Air & Foam <u>No</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 4depth ft. (If NO explain on back side)				- V C - T - H - T - N - T - N - E - N - I - N -		CLAY (NON CAVING) SHALE (BROWN) SANDSTONE (BROWN) SAND STONE (L BROWN) SANDSTONE (GREEN) SANDSTONE (WHITE)		Surface 12 30 75 110 190 225											
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		175 ft. below ground surface				12 in. above grade											
6		NEW PLAIN END SAWMILL A53B GRADE STEEL CASING 18.97#				Surface		84		10. Pump Test Pumping level 205 ft. below surface Pumping at 10 GP M for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)																	
6		DRIVE WELDED																							
7. Grout or Other Sealing Material Method 1IN OUTSIDE TREMMIE PIPE Kind of Sealing Material NEAT CEMENT PRESSURE GROUTED														From (ft.) Surface				To (ft.) 84				# Sacks Cement 35 S			
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?																									
13. Constructor / Supervisory Driller GNP										Lic #		Date Signed 09-09-2002													
Drill Rig Operator DS										Lic or Reg #		Date Signed 09-06-2002													

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 10-02-2002

Updated On: 10-08-2002

Review Status: