Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QR616

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STULZMAN, MARVIN			Phone #
Mailing Address: 11723 KLANG DR			
City: CAZENOVIA	State: WI	Zip Code: 53924	
County: Richland	Co. Permit #	Notification #	Completed: 09-05-2002

Well Constructor (Business Name): AAA QUAL WD/DIV WE TRKING HILLSBORO	Lic. #: 6723	Facility ID # (Public Wells)	
Address: S1595 SCENIC DR HILLSBORO WI 54634		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of WESTFORD

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SW NE or Govt Lot #	Section	Township	Range
	11	12 N	2 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
FIRST ON SITE

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	84
6	84	225

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Yes — Rotary - Air & Foam ..... — No
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 4depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	V	C	-	CLAY (NON CAVING)	Surface	12
T	-	H	-	SHALE (BROWN)	12	30
T	-	N	-	SANDSTONE (BROWN)	30	75
T	-	N	-	SAND STONE (L BROWN)	75	110
E	-	N	-	SANDSTONE (GREEN)	110	190
I	-	N	-	SANDSTONE (WHITE)	190	225

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PLAIN END SAWMILL A53B GRADE STEEL CASING 18.97#	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	DRIVE WELDED		

7. Grout or Other Sealing Material

Method 1IN OUTSIDE TREMMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT PRESSURE GROUTED	Surface	84	35 S

9. Static Water Level
175 ft. below ground surface

10. Pump Test
Pumping level 205 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GNP		09-09-2002
Drill Rig Operator	Lic or Reg #	Date Signed
DS		09-06-2002

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 10-02-2002 Updated On: 10-08-2002 Review Status: