

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QR617		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner AZARIAN, RICK						Phone # (262)534-5428		1. Well Location				Fire # (if avail.)							
Mailing Address PO BOX 606						Town of RIDGEVILLE													
City KANSASVILLE						State WI		Zip Code 53139											
County Monroe		Co. Permit #		Notification #		Completed 09-03-2002		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) AAA QUAL WD/DIV WE TRKING HILLSBORO				Lic. # 6723		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address S1595 SCENIC DR HILLSBORO WI 54634				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 23 16 N 2 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?											
						Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		Construction Type Drilled													
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		189		Rotary - Mud Circulation				- - V C		CLAY (NON CAVING)		Surface		8			
6		189		275		<u>Yes</u> Rotary - Air <u>No</u> <u>Yes</u> Rotary - Air & Foam <u>No</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 4depth ft. (If NO explain on back side)				T - N -		SANDSTONE BROWN		8		20			
										- - L -		LIMESTONE		20		110			
										T - N -		SANDSTONE BROWN		110		160			
										T - N -		SANDSTONE L BROWN		160		210			
										E - N -		SANDSTONE GREEN		210		275			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		220 ft. below ground surface				18 in. above grade					
6		NEW PLAIN END SAWHILL A53 B GRADE STEEL CASING 18.97 #/FT .280 WELL THICKNESS BUTT TO BUTT WELDED W/6" DIAMETER DRIVE SHOE WELDED				Surface		189		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 255 ft. below surface Pumping at 10 GP M for 2 Hrs. Pumping Method ?									
										12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?									
7. Grout or Other Sealing Material												13. Constructor / Supervisory Driller				Lic #		Date Signed	
Method 1 IN OUTSIDE TREMMIE PIPE												GNP						09-09-2002	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Drill Rig Operator				Lic or Reg #		Date Signed					
NEAT CEMENT PRESSURE GROUTED		Surface		189		70 S		DS						09-05-2002					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 10-02-2002

Updated On: 10-08-2002

Review Status: