Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QR627

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MUELLENBERG, JEFF			Phone #
Mailing Address: 27245 NEWELL RD			
City: NORWALK	State: WI	Zip Code: 54648	
County: Monroe	Co. Permit #	Notification #	Completed: 09-22-2002

Well Constructor (Business Name): AAA QUAL WD/DIV WE TRKING HILLSBORO	Lic. #: 6723	Facility ID # (Public Wells)	
Address: S1595 SCENIC DR HILLSBORO WI 54634		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of SHELDON
Fire # (if avail.)
Street Address or Road Name and Number

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code

NE NW or Govt Lot #	Section: 16	Township: 15 N	Range: 2 W	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	108
6	168	365

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit ____in. dia... — No
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 4depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	V	C	-	CLAY NON CAVING	Surface	12
T	-	N	-	SANDSTONE BROWN	12	80
T	-	N	-	SANDSTONE L BROWN	80	130
E	-	H	-	SHALE GREEN	130	205
T	-	H	-	SHALE BROWN	205	260
T	-	N	-	SANDSTONE L BROWN	260	330
I	-	N	-	SANDSTONE WHITE	330	365

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW P.E. WHEATLAND A53B GRADE SLT CASING 18.97# PER FOOT .280 WELL THICKNESS BUTT TO BUTT WELDED	Surface	168
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method 1 IN OUTSIDE TREMMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT PRESSURE GROUTED	Surface	168	70 S

9. Static Water Level
290 ft. below ground surface

10. Pump Test
Pumping level 345 ft. below surface
Pumping at 8 GP M for 1.5 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GNP		10-07-2002
Drill Rig Operator	Lic or Reg #	Date Signed
DS		09-22-2002

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 11-26-2002 Updated On: 12-03-2002 Review Status: