Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QR756

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OTHE, DALE			Phone #
Mailing Address: 3414 RT 5 W			
City: HAZEL GREEN	State: WI	Zip Code: 53811	
County: Burnett	Co. Permit #	Notification #	Completed: 02-05-2002

Well Constructor (Business Name): DMB DRILLING CO INC	Lic #: 6749	Facility ID # (Public Wells)
Address: 3142 15TH ST FREDERIC WI 54837		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 3

1. Well Location

Town of SWISS

Fire # (if avail.)

Street Address or Road Name and Number: TOWER RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SW	NE	Section	Township	Range
or Govt Lot #		25	41 N	16 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	97

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	42
-	-	Z	-	CLAY & GRAVEL	42	73
-	-	G	-	BIG BOULDERS	73	78
-	-	Z	M	CLAY & GRAVEL & SILT	78	88
-	-	Y	-	GRAVEL & SAND	88	97

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO STEEL ASTM A-53 18.97 .280 WALL WELDED JOINT	Surface	93
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	TELESCOPE STAINELSS 25 SLOT	92	97

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 30 GP for 1 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DMB		02-05-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		12
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 03-25-2002 Updated On: 03-25-2002 Review Status: