Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QR914

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WELCOME HOMES	Phone #: (715)635-5261
Mailing Address: N6726 10TH ST	
City: SPOONER	State: WI — Zip Code: 54801
County: Washburn	Co. Permit #:
Notification #	Completed: 08-05-2004
Well Constructor (Business Name): BEECROFT JEREMY WELL DRLG& PUMP REP	Lic. #: 6458
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: W8203 CO HWY A SPOONER WI 54801	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #	Common Well #
Specific Capacity: 2.1	

1. Well Location

Town of SPOONER

Fire # (if avail.)

Street Address or Road Name and Number: CRYSTAL MOUNTAIN RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NE	NE	Section	Township	Range
or Govt Lot #		25	39 N	12 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	92

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	20
-	-	Z	-	GRAVEL & CLAY	20	75
-	-	G	-	GRAVEL	75	92

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR 17 PVC CASING	Surface	87
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
	18 STAINLESS STEEL SCREEN	87	92

9. Static Water Level

38 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
AQUA GROUT BENSEAL	Surface	87	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		09-03-2004
Drill Rig Operator	Lic or Reg #	Date Signed
J		08-12-2004

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		50
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 10-15-2004 Updated On: 10-15-2004 Review Status: