Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QS501

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SPR PUMP, DOHN, TED	Phone #: (414)640-4035
Mailing Address: S104 W18581 KEISER	
City: MUSKEGO	State: WI — Zip Code: 53126
County: Racine	Co. Permit #:	Notification #:	Completed: 01-30-2002
Well Constructor (Business Name): ANHALT WELL & PUMP	Lic. #: 6726	Facility ID # (Public Wells):
Address: 7318 IRELAND DR, HARTFORD WI 53027	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.8

1. Well Location
Town of NORWAY
Fire # (if avail.):
Street Address or Road Name and Number: 3621 ARBOR RD
Subdivision Name: | Lot #: | Block #:
Latitude / Longitude in Decimal Degree (DD): 42.7643 °N -88.1737 °W
Method Code: GCD013
SE NE or Govt Lot #: | Section: 31 | Township: 4 N | Range: 20 E

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?: NEW 2-FAMILY
Construction Type: Drilled

3. Well serves 1 # of HOME 2 FAMILY
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	203

Upper Enlarged Drillhole / Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Yes Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	16
-	-	G	-	GRAVEL	16	24
G	-	C	-	GREY CLAY	24	92
-	-	P	-	HARDPAN	92	113
-	-	L	-	LIMESTONE	113	197
R	S	H	-	SOFT RED SHALE	197	203

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL A53-B P/E 18.97 LB/FT, WELDED NEW	Surface	113
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
28 ft. below ground surface

10. Pump Test
Pumping level 65 ft. below surface
Pumping at 30 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface		

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NO WELLS

13. Constructor / Supervisory Driller	Lic #	Date Signed
AA		01-31-2002
Drill Rig Operator	Lic or Reg #	Date Signed
AA		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Foundation Drain to Clearwater		25
Clearwater Sump		45	Sewer - Building Sanitary		55

Comment:

Created On: 03-01-2002 Updated On: 06-28-2019 Review Status: