

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QS501		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SPR PUMP, DOHN, TED						Phone # (414)640-4035		1. Well Location				Fire # (if avail.)					
Mailing Address S104 W18581 KEISER						Town of NORWAY											
City MUSKEGO						State WI		Zip Code 53126									
County Racine		Co. Permit #		Notification #		Completed 01-30-2002		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) ANHALT WELL & PUMP				Lic. # 6726		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.7643 °N -88.1737 °W				Method Code GCD013					
Address 7318 IRELAND DR HARTFORD WI 53027				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 31 4 N 20 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW 2-FAMILY									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.8													
3. Well serves 1 # of HOME 2 FAMILY Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) 6		From (ft.) Surface		To (ft.) 203		Upper Enlarged Drillhole Lower Open Bedrock		Geology Codes - - C - CLAY - - G - GRAVEL G - C - GREY CLAY - - P - HARDPAN - - L - LIMESTONE R S H - SOFT RED SHALE		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) Surface To (ft.) 16 16 24 24 92 92 113 113 197 197 203					
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.) 6		Material, Weight, Specification SAWHILL A53-B P/E 18.97 LB/FT, WELDED NEW				From (ft.) Surface		To (ft.) 113		28 ft. below ground surface		18 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 65 ft. below surface Pumping at 30 GP M for 1 Hrs. Pumping Method ?		Developed ? Yes Disinfected ? Yes Capped ? Yes					
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NO WELLS					
Kind of Sealing Material CRUMBLES		From (ft.) Surface		To (ft.)		# Sacks Cement											
13. Constructor / Supervisory Driller AA												Lic #		Date Signed 01-31-2002			
Drill Rig Operator AA												Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Foundation Drain to Clearwater		25
Clearwater Sump		45	Sewer - Building Sanitary		55

Comment:

Created On: 03-01-2002

Updated On: 06-28-2019

Review Status: