Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QT321

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	NOGAJCZYK, JOZEF
Phone #	
Mailing Address	2027 8TH AVE
City	FRIENDSHIP
State	WI
Zip Code	53934
County	Adams
Co. Permit #	
Notification #	
Completed	06-30-2002
Well Constructor (Business Name)	PATTEN'S WELL & SEPTIC PUMPING SERV
Lic. #	6580
Facility ID # (Public Wells)	
Address	1555 STATE RD 21 ARKDALE WI 54613-4703
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	1.6

1. Well Location

Town of ADAMS	
Fire # (if avail.)	2027
Street Address or Road Name and Number	2027 8TH AVE
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	43.9629 °N -89.7399 °W
Method Code	GCD013
SE NE or Govt Lot #	
Section	11
Township	17 N
Range	6 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Driven Point

3. Well serves # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	42
1.25	42	45

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	A	S	-	COARSE SAND	Surface	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	GALVINIZED WHEATLAND R&D THREAD 157.50#	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	JOHNSON STAINLESS 7 SLOT	42	45

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 11 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BP		
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BP		06-30-2002

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60

Type	Qualifier	Distance
Building Overhang		3
Septic or Holding, or POWTS Tank	>	30

Comment:

Created On: 09-20-2002 Updated On: 05-04-2020 Review Status: