# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* QT325

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | | | |
|---|---|---|---|
| Property Owner: FREDERICK, PENELOPE P | | | Phone #: (715)325-3101 |
| Mailing Address: 919 CO RD D | | | |
| City: NEKOOSA | State: WI | Zip Code: 54457 | |
| County: Adams | Co. Permit #: | Notification #: | Completed: 08-16-2002 |

**1. Well Location**

Town of ROME

Fire # (if avail.):

Street Address or Road Name and Number: 919 CO RD D

| Subdivision Name | Lot # | Block # |
|---|---|---|
| LAKE FOREST | 1 | |

| Well Constructor (Business Name) | Lic. # | Facility ID # (Public Wells) |
|---|---|---|
| PATTEN'S WELL & SEPTIC PUMPING SERV | 6580 | |

Latitude / Longitude in Decimal Degree (DD): 44.2201 °N -89.7624 °W

Method Code: GCD013

Well Plan Approval #:

| NE | SE | Section | Township | Range |
|---|---|---|---|---|
| or Govt Lot # | | 10 | 20 N | 6 E |

Address: 1555 STATE RD 21
ARKDALE WI 54613-4703

Approval Date (mm-dd-yyyy):

**2. Well Type** New Well

of previous unique well # constructed in

| Hicap Permanent Well # | Common Well # | Specific Capacity |
|---|---|---|
| | | 1.1 |

Reason for replaced or reconstructed well ?

**3. Well serves** 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Jetted

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 2 | Surface | 63 |
| 1.25 | 63 | 67 |

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Yes Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| - | N | S | - | FINE SAND | Surface | 24 |
| - | A | S | G | COURSE SAND WITH FINE GRAVEL | 24 | 67 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 2 | WHEATLAND GALVINIZED R&D THREADED | Surface | 63 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| 1.25 | JOHNSON STAINLESS 7 SLOT | 63 | 67 |

**9. Static Water Level**

12 ft. below ground surface

**10. Pump Test**

Pumping level 26 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

**11. Well Is**

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

**7. Grout or Other Sealing Material**

Method

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| | Surface | | |

**12.** Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NO OTHER WELLS

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| BP | | 08-26-2002 |
| Drill Rig Operator | Lic or Reg # | Date Signed |
| | | |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance |
|---|---|---|
| Building Overhang | | 3 |

Comment:

Created On: 10-02-2002 Updated On: 05-04-2020 Review Status: