

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QT325		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																			
Property Owner FREDERICK, PENELOPE P						Phone # (715)325-3101		1. Well Location				Fire # (if avail.)																	
Mailing Address 919 CO RD D						Town of ROME						Street Address or Road Name and Number 919 CO RD D																	
City NEKOOSA				State WI		Zip Code 54457																							
County Adams		Co. Permit #		Notification #		Completed 08-16-2002		Subdivision Name LAKE FOREST			Lot # 1		Block #																
Well Constructor (Business Name) PATTEN'S WELL & SEPTIC PUMPING SERV				Lic. # 6580		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.2201 °N -89.7624 °W			Method Code GCD013																
Address 1555 STATE RD 21 ARKDALE WI 54613-4703				Well Plan Approval #				NE SE Section Township Range or Govt Lot # 10 20 N 6 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Jetted																			
				Approval Date (mm-dd-yyyy)																									
Hicap Permanent Well #			Common Well #			Specific Capacity 1.1			3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes			Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes			Common Well #			Specific Capacity 1.1																							
4. Potential Contamination Sources - ON REVERSE SIDE																													
5. Drillhole Dimensions and Construction Method												8. Geology																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)											
2		Surface		63		Rotary - Mud Circulation				Rotary - Air		Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		- N S - FINE SAND Surface 24		- A S G COURSE SAND WITH FINE GRAVEL 24 67	
1.25		63		67		Yes				Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		- N S - FINE SAND Surface 24		- A S G COURSE SAND WITH FINE GRAVEL 24 67							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface				20 in. above grade															
2		WHEATLAND GALVINIZED R&D THREADED				Surface		63		10. Pump Test				Developed ? Yes															
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 26 ft. below surface				Disinfected ? Yes															
1.25		JOHNSON STAINLESS 7 SLOT				63		67		Pumping at 15 GP M for 2 Hrs.				Capped ? Yes															
7. Grout or Other Sealing Material												Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NO OTHER WELLS													
Method												13. Constructor / Supervisory Driller								Lic #		Date Signed							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		BP				08-26-2002		Drill Rig Operator		Lic or Reg #		Date Signed									
Surface				Surface		Surface		Surface		NO OTHER WELLS				08-26-2002		08-26-2002		08-26-2002											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		3

Comment:

Created On: 10-02-2002

Updated On: 05-04-2020

Review Status: