Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QV183

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SNAPP, GREG	Phone #: (262)749-0773
Mailing Address: 3060 PIPPER RD	
City: WHITEWATER	State: WI — Zip Code: 53190
County: Jefferson	Co. Permit #:
Notification #: 22511748	Completed: 06-09-2006
Well Constructor (Business Name): ROCK JOHNSON	Lic. #: 6433
Facility ID # (Public Wells):	
Address: DRILL-IT LAKE GENEVA WI 53417	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location

Town of COLD SPRINGS				Fire # (if avail.): 3060
Street Address or Road Name and Number: 3060 PIPER RD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 42.8738 °N -88.6865 °W				Method Code: GCD013
NE / SE or Govt Lot #:	Section: 23	Township: 5 N	Range: 15 E	

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	4
6	4	98

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / No — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	G	SAND, GRAVEL, ROCKS	Surface	20
-	-	Y	C	SAND, GRAVEL, CLAY	20	40
-	-	Y	-	SAND, GRAVEL	40	70
G	-	C	-	GRAY CLAY	70	80
-	-	Y	-	SAND, GRAVEL	80	90
-	-	L	-	LIMEROCK	90	98

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 PE .280 ASTM A53 SAWHILL PLAIN END	Surface	90
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 10 GP M for 12 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method POURED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CETCO	Surface	4	3 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RJ		06-16-2006
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
NE		06-16-2006

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		4	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 07-11-2006 Updated On: 09-26-2019 Review Status: