

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QV186		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner WALLACE, JASON						Phone # (262)749-0773		1. Well Location				Fire # (if avail.)	
Mailing Address 33633 BOHNER DR						Town of BURLINGTON						Street Address or Road Name and Number 33633 BOHNER DR	
City BURLINGTON			State WI		Zip Code 53105		Subdivision Name			Lot #		Block #	
County Racine		Co. Permit #		Notification # 23247505		Completed 07-04-2006		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code		
Well Constructor (Business Name) ROCK JOHNSON				Lic. # 6433		Facility ID # (Public Wells)		SW NW Section Township Range or Govt Lot # 20 2 N 19 E		2. Well Type Replacement of previous unique well # NS841 constructed in 2004			
Address DRILL-IT LAKE GENEVA WI 53417				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ?					
Hicap Permanent Well #			Common Well #		Specific Capacity 0.8		Construction Type Drilled						
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
8		Surface		5		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 6in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)			Yes No				
6		5		48									
5		48		51									
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T - Y -		BROWN SAND, GRAVEL				Surface		51					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		WHEATLAND WR US ASTM A53 6.625 X .280 GR BE				Surface		48					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
5		ALLOY MACHINE 20 SLOT				48		51					
7. Grout or Other Sealing Material Method POURED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
CETCO #8 GRANULAR		Surface		48		3 S							
9. Static Water Level 28 ft. below ground surface													
10. Pump Test Pumping level 41 ft. below surface Pumping at 10 GP M for 24 Hrs. Pumping Method ?													
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
PJ								07-05-2006					
Drill Rig Operator						Lic or Reg #		Date Signed					
								07-04-2006					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		11	Collector Sewer - San or Storm		53
			Sewer - Building Sanitary		50

Comment:

Created On: 07-20-2006

Updated On: 09-14-2006

Review Status: