Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QV458

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LEISSO, JOHN	Phone #: (608)457-2693
Mailing Address: W776 CHIPMUNK RIDGE	
City: STODDARD	State: WI — Zip Code: 54658
County: Vernon	Co. Permit #: — Notification #: — Completed: 06-07-2002
Well Constructor (Business Name): SYLVESTER R HAUPT	Lic. #: 489 — Facility ID # (Public Wells):
Address: 5847 3RD ST AUBURNDALE WI 54412	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of BERGEN

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SE SW or Govt Lot #: — Section: 11 — Township: 14 N — Range: 7 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

OTHER WELL CAVED IN

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	203
6	203	520

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 4depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	36
-	-	L	-	LIMESTONE	36	150
T	-	H	-	BROWN SHALE	150	475
T	-	N	-	BROWN SANDSTONE	475	500
I	-	N	-	WHITE SANDSTONE	500	520

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B 280 WALL WELDED U.S. SAWHILL	Surface	203
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PACKER PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	203	56 S

9. Static Water Level

371 ft. below ground surface

10. Pump Test

Pumping level 450 ft. below surface

Pumping at 19 GP for 1 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
SH		06-12-2002
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TP		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Building Overhang		63
			Septic or Holding, or POWTS Tank		85

Comment:

Created On: 07-09-2002 Updated On: 07-09-2002 Review Status: