Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QW367

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHICKLING, WAYNE			Phone #: (715)262-5027
Mailing Address: 145 BROAD ST			
City: PRESCOTT	State: WI	Zip Code: 54021	
County: Burnett	Co. Permit #:	Notification #:	Completed: 10-25-2003

Well Constructor (Business Name): WEBSTER HARDWARE HANK INC	Lic. #: 6033	Facility ID # (Public Wells):	
Address: PO BOX 130 WEBSTER WI 54893		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 6.7	

1. Well Location

Town of UNION			Fire # (if avail.): 27624
Street Address or Road Name and Number: 27624 SHADY GLEN RD			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 45.9179 °N -92.424 °W			Method Code: GCD013

SW	SW	Section	Township	Range
or Govt Lot #		25	40 N	17 W

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: NON-COMPLIANT-SLOW FLOW-F

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4.5	Surface	5.5
4	5.5	37

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	Q	Y	M	RED SILT, SAND, GRAVEL, COBBLES C	Surface	7
R	Q	Y	M	RED SILT, SAND, GRAVEL C	7	37

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4.5	WHITEWATER PITLESS ADAPTER MODEL SU4-5 1/2	Surface	5.5
4	IPSCO STEEL USA ASTM A53 4.5 X .237 10.79#/FT	5.5	34
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	12 SLOT US SCREEN CONTINUOUS SLOT STAINLESS	34	37

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 11 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
WSA		10-31-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		52	Shoreline/Pool		105
Building Overhang		5	Sewer - Building Sanitary		30
Downspout/Yard Hydrant		28	Septic or Holding, or POWTS Tank		52

Comment:

Created On: 12-10-2003 Updated On: 06-30-2020 Review Status: